

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Apr/ 2020

Date of creation: 01/05/2020 04:10

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/04/20	V	0.00	V	0.00	V	23.18	V	0.00	V	48.26	V	0.02
02/04/20	T	0.00	T	0.00	T	0.00	T	0.00	T	31.05	T	0.02
03/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
04/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
05/04/20	V	0.00	V	0.00	V	0.21	V	0.00	V	15.12	V	0.02
06/04/20	V	0.00	V	0.00	V	15.58	V	0.00	V	6.12	V	0.10
07/04/20	V	0.00	V	0.00	V	3.11	V	0.00	V	2.37	V	0.07
08/04/20	V	0.00	V	0.00	V	0.00	V	0.00	V	8.72	V	0.10
09/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
10/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
11/04/20	V	0.00	V	0.00	V	0.00	V	0.00	V	25.03	V	0.10
12/04/20	V	0.00	V	0.00	V	0.00	V	0.00	V	7.68	V	0.05
13/04/20	V	0.00	V	0.00	V	0.00	V	0.00	V	18.86	V	0.24
14/04/20	V	0.00	V	0.00	V	0.00	V	0.00	V	12.15	V	0.03
15/04/20	V	0.00	V	0.00	V	0.00	V	0.00	V	10.64	V	0.09
16/04/20	V	0.00	V	0.00	V	1.50	V	0.00	V	6.28	V	0.11
17/04/20	V	0.00	V	0.00	V	0.00	V	0.00	V	10.28	V	0.43
18/04/20	V	0.00	V	0.00	V	0.00	V	0.00	V	19.19	V	0.28
19/04/20	V	0.00	V	0.00	V	0.00	V	0.00	V	18.03	V	0.26
20/04/20	V	0.00	V	0.00	V	1.48	V	0.00	V	11.76	V	0.95
21/04/20	V	0.00	V	0.00	V	0.00	V	0.00	V	10.52	V	0.16
22/04/20	V	0.04	V	0.00	V	10.74	V	0.00	V	11.30	V	0.16
23/04/20	V	0.24	V	0.00	V	7.65	V	0.00	V	4.19	V	0.09
24/04/20	V	0.27	V	0.00	V	3.02	V	0.00	V	0.96	V	0.12
25/04/20	V	0.29	V	0.00	V	14.08	V	0.00	V	6.02	V	0.29
26/04/20	V	0.24	V	0.00	V	10.87	V	0.00	V	1.91	V	0.17
27/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
28/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
29/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
30/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
MAV		0.06		0.00		4.26		0.00		11.25		0.19

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Apr/ 2020

Date of creation: 01/05/2020 04:10

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/04/20	V	61.02	V	8.95	V	10.74	V	44.64	V	997.21	V	99687.50
02/04/20	T	54.74	T	8.70	T	12.77	T	48.71	T	993.93	T	106582.66
03/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
04/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
05/04/20	V	58.45	V	8.98	V	10.14	V	43.73	V	1021.21	V	99029.74
06/04/20	V	118.57	V	8.72	V	12.41	V	48.40	V	1020.90	V	104644.81
07/04/20	V	152.08	V	9.49	V	14.62	V	52.62	V	1016.11	V	114988.78
08/04/20	V	125.54	V	7.99	V	14.87	V	52.82	V	1016.38	V	105478.91
09/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
10/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
11/04/20	V	51.20	V	8.31	V	14.41	V	52.39	V	1014.03	V	99891.69
12/04/20	V	56.31	V	9.45	V	14.43	V	52.22	V	1006.30	V	106745.71
13/04/20	V	50.09	V	9.52	V	14.51	V	51.47	V	990.56	V	106263.06
14/04/20	V	51.90	V	9.16	V	14.73	V	52.10	V	996.23	V	110524.41
15/04/20	V	55.95	V	9.55	V	14.53	V	51.57	V	996.17	V	112092.17
16/04/20	V	86.67	V	8.40	V	14.63	V	51.61	V	991.66	V	109707.34
17/04/20	V	94.72	V	8.10	V	14.82	V	52.34	V	998.82	V	111097.82
18/04/20	V	119.75	V	7.57	V	15.64	V	53.96	V	1004.07	V	111025.01
19/04/20	V	73.47	V	8.09	V	15.94	V	54.61	V	1006.22	V	114638.43
20/04/20	V	86.50	V	8.96	V	14.90	V	52.90	V	1012.75	V	115872.04
21/04/20	V	81.24	V	9.36	V	13.94	V	51.07	V	1014.20	V	110952.08
22/04/20	V	77.99	V	8.21	V	14.60	V	52.24	V	1013.34	V	108581.32
23/04/20	V	105.89	V	8.99	V	14.32	V	51.80	V	1006.21	V	110829.59
24/04/20	V	60.17	V	9.31	V	15.62	V	53.24	V	993.69	V	103831.27
25/04/20	V	98.41	V	8.82	V	15.15	V	52.69	V	988.69	V	106446.16
26/04/20	V	118.17	V	8.50	V	15.78	V	53.82	V	994.58	V	103640.18
27/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
28/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
29/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
30/04/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
MAV		86.35		8.78		14.48		51.81		1003.94		108389.69

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita

Plant: Kauno kogeneracinė jėgainė

Report time: Apr/ 2020

Date of creation: 01/05/2020 04:10

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/04/20	V	913.69				
02/04/20	V	939.88				
03/04/20	N	0.00				
04/04/20	N	0.00				
05/04/20	V	928.40				
06/04/20	V	955.88				
07/04/20	V	958.33				
08/04/20	V	985.55				
09/04/20	N	0.00				
10/04/20	N	0.00				
11/04/20	V	960.38				
12/04/20	V	964.55				
13/04/20	V	963.01				
14/04/20	V	988.75				
15/04/20	V	985.59				
16/04/20	V	1013.84				
17/04/20	V	1020.26				
18/04/20	V	1039.15				
19/04/20	V	1039.18				
20/04/20	V	1020.46				
21/04/20	V	1017.67				
22/04/20	V	1031.58				
23/04/20	V	1024.85				
24/04/20	V	1014.73				
25/04/20	V	1032.52				
26/04/20	V	1041.80				
27/04/20	N	0.00				
28/04/20	N	0.00				
29/04/20	N	0.00				
30/04/20	N	0.00				
MAV		998.20				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value