

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jun/ 2020

Date of creation: 01/07/2020 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/06/20	V	0.07	V	0.00	V	0.74	V	0.00	V	1.41	V	0.04
02/06/20	V	0.15	V	0.00	V	0.65	V	0.00	V	5.83	V	0.12
03/06/20	V	0.09	V	0.00	V	0.67	V	0.00	V	0.02	V	0.03
04/06/20	V	0.09	V	0.00	V	0.68	V	0.00	V	0.13	V	0.08
05/06/20	V	0.16	V	0.00	V	0.77	V	0.00	V	0.00	V	0.09
06/06/20	V	0.09	V	0.00	V	0.79	V	0.00	V	3.06	V	0.13
07/06/20	V	0.16	V	0.00	V	0.75	V	0.00	V	0.00	V	0.10
08/06/20	V	0.15	V	0.00	V	0.68	V	0.00	V	3.81	V	0.05
09/06/20	M	0.14	M	0.00	M	0.69	M	0.00	M	0.15	M	0.10
10/06/20	V	0.15	V	0.00	V	0.81	V	0.00	V	6.36	V	0.01
11/06/20	V	0.19	V	0.00	V	0.91	V	0.00	V	2.66	V	0.05
12/06/20	V	0.18	V	0.00	V	0.82	V	0.00	V	9.50	V	0.06
13/06/20	V	0.17	V	0.00	V	0.90	V	0.00	V	3.68	V	0.11
14/06/20	V	0.14	V	0.00	V	1.21	V	0.00	V	0.28	V	0.05
15/06/20	V	0.04	V	0.00	V	0.84	V	0.00	V	1.97	V	0.01
16/06/20	V	0.11	V	0.00	V	0.85	V	0.00	V	1.38	V	0.16
17/06/20	V	0.14	V	0.00	V	0.87	V	0.00	V	2.87	V	0.06
18/06/20	M	0.11	V	0.00	V	0.49	V	0.00	V	0.06	V	0.08
19/06/20	V	0.00	V	0.00	V	1.11	V	0.00	V	1.97	V	0.42
20/06/20	V	0.00	V	0.00	V	0.83	V	0.00	V	0.63	V	0.08
21/06/20	V	0.00	V	0.00	V	0.72	V	0.00	V	0.18	V	0.55
22/06/20	V	0.00	V	0.00	V	0.88	V	0.00	V	0.40	V	0.28
23/06/20	V	0.00	V	0.00	V	0.71	V	0.00	V	0.29	V	0.26
24/06/20	V	0.01	V	0.00	V	0.71	V	0.00	V	0.22	V	0.26
25/06/20	V	0.00	V	0.00	V	0.83	V	0.00	V	0.04	V	0.14
26/06/20	V	0.00	V	0.00	V	0.78	V	0.00	V	0.33	V	0.21
27/06/20	V	0.00	V	0.00	V	0.66	V	0.00	V	0.06	V	0.29
28/06/20	V	0.01	V	0.00	V	0.65	V	0.00	V	0.14	V	1.38
29/06/20	V	0.01	V	0.00	V	0.71	V	0.00	V	0.11	V	0.31
30/06/20	V	0.01	V	0.00	V	0.73	V	0.00	V	0.03	V	2.59
MAV		0.08		0.00		0.78		0.00		1.60		0.28

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita

Plant: Kauno kogeneracinė jėgainė

Report time: Jun/ 2020

Date of creation: 01/07/2020 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
01/06/20	V	77.80	V	8.66	V	14.83	V	52.56	V	1006.99	V	96722.20
02/06/20	V	61.14	V	8.30	V	15.66	V	53.74	V	1000.86	V	93118.29
03/06/20	V	68.11	V	9.06	V	15.90	V	53.48	V	994.62	V	86106.01
04/06/20	V	75.51	V	8.41	V	16.29	V	53.84	V	989.32	V	85482.52
05/06/20	V	81.26	V	8.70	V	16.30	V	53.72	V	986.73	V	86095.55
06/06/20	V	83.93	V	8.70	V	15.59	V	52.29	V	990.51	V	85294.78
07/06/20	V	74.41	V	8.74	V	13.94	V	49.30	V	997.07	V	81506.32
08/06/20	V	65.17	V	8.82	V	13.00	V	47.02	V	996.53	V	80367.97
09/06/20	M	72.70	M	8.57	M	13.04	V	48.87	V	1000.92	V	93138.74
10/06/20	V	122.93	V	9.07	V	17.26	V	54.70	V	1000.06	V	87675.27
11/06/20	V	152.90	V	8.62	V	17.82	V	55.27	V	999.14	V	90904.60
12/06/20	V	116.04	V	8.48	V	15.39	V	51.41	V	1001.07	V	89146.31
13/06/20	V	150.18	V	8.01	V	14.03	V	49.57	V	1004.35	V	102391.74
14/06/20	V	131.42	V	8.31	V	13.19	V	48.63	V	1003.56	V	96880.68
15/06/20	V	121.41	V	8.43	V	15.56	V	52.10	V	1001.10	V	94990.18
16/06/20	V	140.17	V	8.69	V	16.12	V	53.36	V	1001.70	V	92014.22
17/06/20	V	116.70	V	8.06	V	16.41	V	54.29	V	1000.04	V	91229.22
18/06/20	V	87.13	M	6.32	V	15.73	V	54.41	V	997.93	V	89708.67
19/06/20	V	127.28	V	8.53	V	16.55	V	55.51	V	999.68	V	109665.52
20/06/20	V	59.88	V	8.80	V	15.80	V	54.38	V	999.24	V	90664.56
21/06/20	V	66.75	V	8.76	V	15.99	V	54.64	V	1000.86	V	90600.59
22/06/20	V	109.95	V	8.45	V	17.95	V	57.04	V	1001.60	V	90861.13
23/06/20	V	120.86	V	8.06	V	18.73	V	58.32	V	1004.44	V	90558.28
24/06/20	V	148.82	V	7.97	V	18.69	V	58.77	V	1010.72	V	89631.91
25/06/20	V	146.23	V	8.06	V	18.52	V	58.66	V	1013.75	V	90021.29
26/06/20	V	135.10	V	8.15	V	18.98	V	58.92	V	1010.72	V	87601.02
27/06/20	V	145.23	V	8.25	V	18.69	V	58.35	V	1002.34	V	89266.67
28/06/20	V	138.76	V	8.10	V	19.82	V	58.92	V	997.14	V	88130.30
29/06/20	V	125.03	V	8.23	V	19.95	V	58.98	V	995.44	V	88966.34
30/06/20	V	140.09	V	8.19	V	20.09	V	59.31	V	991.15	V	90482.51
MAV		109.25		8.38		16.60		54.45		999.97		90585.71

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita

Plant:

Report time: Jun/ 2020

Date of creation: 01/07/2020 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/06/20	V	995.47				
02/06/20	V	1001.01				
03/06/20	V	984.44				
04/06/20	V	988.62				
05/06/20	V	993.36				
06/06/20	V	990.89				
07/06/20	V	985.84				
08/06/20	V	980.22				
09/06/20	M	983.09				
10/06/20	V	933.32				
11/06/20	V	950.32				
12/06/20	V	958.65				
13/06/20	V	968.84				
14/06/20	V	991.75				
15/06/20	V	970.99				
16/06/20	V	977.47				
17/06/20	V	982.96				
18/06/20	V	988.59				
19/06/20	V	978.54				
20/06/20	V	988.23				
21/06/20	V	1002.94				
22/06/20	V	1015.64				
23/06/20	V	1035.35				
24/06/20	V	1046.40				
25/06/20	V	1047.34				
26/06/20	V	1040.21				
27/06/20	V	1035.36				
28/06/20	V	1042.34				
29/06/20	V	1040.25				
30/06/20	V	1042.85				
MAV		998.71				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value