

Mėnesinė ataskaita

Plant: Kauno kogeneracinė jėgainė

Report time: Jul/ 2020

Date of creation: 01/08/2020 04:30

Date	Dulkės		HCl		SO ₂		HF		CO		BOA	
	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³	Unit:	mg/Nm ³
	DLV:	10.00	DLV:	10.00	DLV:	50.00	DLV:	1.00	DLV:	50.00	DLV:	10.00
01/07/20	V	0.00	V	0.00	V	0.74	V	0.00	V	0.05	V	1.62
02/07/20	V	0.00	V	0.00	V	0.74	V	0.00	V	0.05	V	1.27
03/07/20	V	0.00	V	0.00	V	0.81	V	0.00	V	3.22	V	1.35
04/07/20	V	0.01	V	0.00	V	0.67	V	0.00	V	0.07	V	0.72
05/07/20	V	0.12	V	0.00	V	0.85	V	0.00	V	71.94	V	2.62
06/07/20	V	0.10	V	0.00	V	0.81	V	0.00	V	0.28	V	1.01
07/07/20	V	0.01	V	0.00	V	0.81	V	0.00	V	0.02	V	1.13
08/07/20	V	0.00	V	0.00	V	0.78	V	0.00	V	0.76	V	0.82
09/07/20	V	0.03	V	0.00	V	0.66	V	0.00	V	3.61	V	0.48
10/07/20	V	0.00	V	0.00	V	0.65	V	0.00	V	1.86	V	0.55
11/07/20	V	0.00	V	0.00	V	0.67	V	0.00	V	0.41	V	0.88
12/07/20	V	0.01	V	0.00	V	0.66	V	0.00	V	0.20	V	0.90
13/07/20	V	0.00	V	0.00	V	0.67	V	0.00	V	0.19	V	0.78
14/07/20	V	0.00	V	0.00	V	0.67	V	0.00	V	0.60	V	0.87
15/07/20	V	0.00	V	0.00	V	0.64	V	0.00	V	0.24	V	0.42
16/07/20	V	0.00	V	0.00	V	0.61	V	0.00	V	0.45	V	0.28
17/07/20	V	0.00	V	0.00	V	0.71	V	0.00	V	0.24	V	0.33
18/07/20	V	0.00	V	0.00	V	0.64	V	0.00	V	0.56	V	0.22
19/07/20	V	0.00	V	0.00	V	0.62	V	0.00	V	1.66	V	0.31
20/07/20	V	0.00	V	0.00	V	0.62	V	0.00	V	1.23	V	0.28
21/07/20	V	0.01	V	0.00	V	1.29	V	0.00	V	2.67	V	0.68
22/07/20	V	0.01	V	0.00	V	0.72	V	0.00	V	0.87	V	1.10
23/07/20	V	0.00	V	0.00	V	0.65	V	0.00	V	0.84	V	0.39
24/07/20	V	0.00	V	0.02	V	0.69	V	0.00	V	0.42	V	0.39
25/07/20	V	0.01	V	0.01	V	0.61	V	0.00	V	0.82	V	0.20
26/07/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
27/07/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
28/07/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
29/07/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
30/07/20	V	0.07	V	0.00	V	1.41	V	0.00	V	11.96	V	0.68
31/07/20	V	0.06	V	0.00	V	0.60	V	0.00	V	17.84	V	0.65
MAV		0.02		0.00		0.73		0.00		3.74		0.77

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Mėnesinė ataskaita



Plant: Kauno kogeneracinė jėgainė

Report time: Jul/ 2020

Date of creation: 01/08/2020 04:30

Date	NOx		O ₂		H ₂ O		Kamino T		Slėgis		Srautas	
	Unit:	mg/Nm ³	Unit:	Vol%	Unit:	Vol%	Unit:	°C	Unit:	hPa	Unit:	Nm ³ /h
	DLV:	200.00										
01/07/20	V	134.56	V	8.13	V	19.72	V	59.23	V	993.64	V	91100.50
02/07/20	V	148.03	V	8.26	V	19.59	V	58.78	V	995.12	V	90315.36
03/07/20	V	145.84	V	8.28	V	19.32	V	58.86	V	999.42	V	90735.27
04/07/20	V	106.94	V	8.12	V	19.16	V	58.71	V	1001.56	V	90029.11
05/07/20	V	118.47	V	11.02	V	17.11	V	55.80	V	996.71	V	94827.62
06/07/20	V	149.50	V	8.64	V	19.75	V	58.77	V	993.83	V	93066.91
07/07/20	V	125.02	V	8.74	V	19.05	V	58.70	V	997.82	V	95292.85
08/07/20	V	129.44	V	8.82	V	17.78	V	57.57	V	999.04	V	95620.89
09/07/20	V	83.02	V	8.29	V	17.22	V	57.19	V	1001.82	V	89949.98
10/07/20	V	105.48	V	8.21	V	18.03	V	57.51	V	998.12	V	91684.15
11/07/20	V	90.08	V	7.82	V	18.52	V	58.32	V	1001.87	V	87232.54
12/07/20	V	75.21	V	8.07	V	17.57	V	57.72	V	1007.56	V	89525.47
13/07/20	V	88.26	V	8.47	V	17.34	V	57.44	V	1006.40	V	92746.52
14/07/20	V	93.22	V	8.27	V	17.67	V	57.58	V	1004.57	V	93602.66
15/07/20	V	79.95	V	8.19	V	17.91	V	57.69	V	1001.24	V	96330.26
16/07/20	V	71.78	V	7.69	V	18.39	V	58.33	V	999.69	V	98552.42
17/07/20	V	91.33	V	7.93	V	18.66	V	58.68	V	1003.46	V	101133.16
18/07/20	V	59.16	V	8.57	V	18.65	V	58.60	V	1007.64	V	99951.78
19/07/20	V	48.79	V	8.55	V	18.56	V	58.40	V	1006.20	V	98531.34
20/07/20	V	48.83	V	8.53	V	18.83	V	58.41	V	1001.53	V	98900.64
21/07/20	V	55.60	V	8.66	V	17.79	V	57.44	V	1001.19	V	101439.48
22/07/20	V	61.75	V	8.64	V	16.96	V	56.76	V	1001.75	V	101011.19
23/07/20	V	64.59	V	8.35	V	17.53	V	57.41	V	1000.80	V	105944.52
24/07/20	V	98.76	V	8.09	V	17.60	V	57.55	V	999.42	V	109405.31
25/07/20	V	86.65	V	7.95	V	18.81	V	58.41	V	997.34	V	104481.98
26/07/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
27/07/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
28/07/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
29/07/20	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
30/07/20	V	90.03	V	10.01	V	18.89	V	58.75	V	1001.74	V	99977.63
31/07/20	V	68.71	V	7.74	V	21.94	V	61.65	V	999.24	V	109683.73
MAV		93.30		8.40		18.48		58.19		1000.74		96722.06

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value

Plant:

Report time: Jul/ 2020

Date of creation: 01/08/2020 04:30

Date	Degimo T					
	Unit: °C	DLV: 850.00				
01/07/20	V	1050.18				
02/07/20	V	1042.36				
03/07/20	V	1035.97				
04/07/20	V	1044.55				
05/07/20	V	936.03				
06/07/20	V	1030.04				
07/07/20	V	1034.11				
08/07/20	V	1026.66				
09/07/20	V	973.92				
10/07/20	V	962.19				
11/07/20	V	994.46				
12/07/20	V	992.90				
13/07/20	V	994.43				
14/07/20	V	995.91				
15/07/20	V	989.62				
16/07/20	V	982.24				
17/07/20	V	985.32				
18/07/20	V	993.21				
19/07/20	V	1000.18				
20/07/20	V	986.41				
21/07/20	V	979.58				
22/07/20	V	973.59				
23/07/20	V	964.05				
24/07/20	V	974.39				
25/07/20	V	1003.06				
26/07/20	N	0.00				
27/07/20	N	0.00				
28/07/20	N	0.00				
29/07/20	N	0.00				
30/07/20	V	949.31				
31/07/20	V	925.39				
MAV		994.79				

The status refer to the plant:

V: Valid T: <2/3 M: Maintenance N: undefined MAV: Month average value